



NO.	ELEV.	DESCRIPTION
1		92 IN X 144 IN FRP WET WELL
	2000.00	RIM
	1988.00	BASE
2		72IN X 66 IN FRP VALVE VAULT
	1994.50	BASE
3	1994.00	IE - 16 IN INLET HUB FOR 12 IN SDR 35 PVC PIPE
		9:00 POSITION
4	1996.00	IE - 6 IN SCH 10 STAINLESS STEEL OUTLET
		3:00 POSITION
5		HYDROMATIC S6LXP2000 PUMPS, 20 HP, 460V/3
		EXPLOSION-PROOF, 600 GPM @ 60 FT TDH
		**SHIPPED LOOSE**
6		HYDROMATIC 6 IN MTM DISCHARGE ELBOW
7		2 IN SCH 40 STAINLESS STEEL SLIDE RAILS
8		LEVEL TRANSDUCER & FLOAT SWITCHES
	1993.50	FLOAT SWITCH - REDUNDANT ON/HIGH LEVEL ALARM
	1993.50	HIGH LEVEL ALARM
	1993.30	LAG PUMP ON
	1993.00	LEAD PUMP ON
	1991.00	PUMP(S) OFF
	1988.50	TRANSDUCER FACE
9		6 IN SCH 10 STAINLESS STEEL DISCHARGE MANIFOLD
10		2 IN SCH 40 PVC DRAIN
11		6 IN LEVER AND WEIGHT CHECK VALVE
12		6 IN RESILIENT SEAT GATE VALVE
13		LADDER
14		ELECTRICAL HAND HOLE JUNCTION BOX ASSEMBLY
		**SHIPPED LOOSE**
15		300 PSF ALUMINUM HATCHES
16		DUPLEX ALTERNATING CONTROL PANEL (NOT SHOWN)
		**SHIPPED LOOSE**

AFS-STN-92-144-72-66-60-SS-EXT  
 PACKAGED LIFT STATION - PROJECT NAME - QT 12345  
 COMPONENT DETAILS

DWG NO.	DATE	SCALE	DRAWN BY	CHECKED BY
XXX	3/15/16	1:36	RJK	N/A

**AFS**  
 AUTOMATED FLOW SYSTEMS

4444 S YELLOWSTONE HWY 4101 E BROADWAY  
 COEUR D'ALENE, ID 83814 IDAHO FALLS, ID 83402  
 SPOKANE, WA 99202  
 208.529.6868 208.529.6868  
 PHONE 208.664.2133

WWW.RCWORST.COM

CUSTOMER APPROVAL: \_\_\_\_\_ DATE: \_\_\_\_\_  
 BY THIS SIGNATURE, CUSTOMER INDICATES THAT HE HAS REVIEWED THIS SUBMITTAL DRAWING AND FOUND THAT IT MEETS ALL OF THE DESIGNER'S FUNCTIONAL REQUIREMENTS AND/OR SPECIFICATIONS. CUSTOMER HEREBY AUTHORIZES RC WORST & CO. INC. TO MANUFACTURE THE CUSTOM PRODUCT IN ACCORDANCE WITH THIS SUBMITTAL DRAWING.