

MVP-S DM CS Reference Chart

Program Code: SI115-61

Input Functions (Timed Dose):

- RO & Low Level Alarm Float
- Timer On & Off Float
- Override Timer On & Off Float
- High Level Alarm Float
- Current Sensor
- Push to Silence/Reset

Condition for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Pump is activated
- Pushbutton is pressed

Input Functions (Demand):

- RO & Low Level Alarm Float
- Off Float
- On Float
- High Level Alarm Float
- Current Sensor
- Push to Silence/Reset

Condition for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Pump is activated
- Pushbutton is pressed

Output Functions:

- Pump
- Level Light
- Pump Fail Light
- Audible Alarm

Condition for activation:

- Pump is called to run
- Alarm Light is activated
- Pump Fail Light is activated
- Audible Alarm is activated

Built In Screens:

Built in screens include: time & date, digital inputs, and digital outputs. To view these screens, press the down arrow repeatedly until a built in screen appears, then use the left and right arrow keys to change between screens.

Alarm and System Data Screens:

Alarm screens appear during alarm conditions. System data screens include float status, pump run data, and alarm activity. Screens with a "T" in the lower right contain totalized values. Screens with a "R" in the lower right contain resettable values. To change between these screens, press the up and down arrow keys.

Selecting Parameters for Viewing or Adjusting:

To begin the process to set parameters, press the down arrow repeatedly until the last screen is shown, then press 'ESC'.

Parameter Names:	Description:	Time Range:	Timed / Demand
HLA Dly	High Level Alarm Delay	MM:SS	Both
Off Time	Timer Off Time	MM:SS	Timed
On Time	Timer On Time	MM:SS	Timed
OVR Off	Override Timer Off Time	MM:SS	Timed
OVR On	Override Timer On Time	MM:SS	Timed
MinOvrTm	Minimum Override Time	MM:SS	Timed
MinRunT	Minimum Run Time	MM:SS	Demand
TimeDose	Time Dose Mode		Both

EIN-CP-REF-150
Rev 7.1 © 01/05/10

MVP-S DM CS Reference Chart

Program Code: SI115-61

Input Functions (Timed Dose):

- RO & Low Level Alarm Float
- Timer On & Off Float
- Override Timer On & Off Float
- High Level Alarm Float
- Current Sensor
- Push to Silence/Reset

Condition for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Pump is activated
- Pushbutton is pressed

Input Functions (Demand):

- RO & Low Level Alarm Float
- Off Float
- On Float
- High Level Alarm Float
- Current Sensor
- Push to Silence/Reset

Condition for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Pump is activated
- Pushbutton is pressed

Output Functions:

- Pump
- Level Light
- Pump Fail Light
- Audible Alarm

Condition for activation:

- Pump is called to run
- Alarm Light is activated
- Pump Fail Light is activated
- Audible Alarm is activated

Built In Screens:

Built in screens include: time & date, digital inputs, and digital outputs. To view these screens, press the down arrow repeatedly until a built in screen appears, then use the left and right arrow keys to change between screens.

Alarm and System Data Screens:

Alarm screens appear during alarm conditions. System data screens include float status, pump run data, and alarm activity. Screens with a "T" in the lower right contain totalized values. Screens with a "R" in the lower right contain resettable values. To change between these screens, press the up and down arrow keys.

Selecting Parameters for Viewing or Adjusting:

To begin the process to set parameters, press the down arrow repeatedly until the last screen is shown, then press 'ESC'.

Parameter Names:	Description:	Time Range:	Timed / Demand
HLA Dly	High Level Alarm Delay	MM:SS	Both
Off Time	Timer Off Time	MM:SS	Timed
On Time	Timer On Time	MM:SS	Timed
OVR Off	Override Timer Off Time	MM:SS	Timed
OVR On	Override Timer On Time	MM:SS	Timed
MinOvrTm	Minimum Override Time	MM:SS	Timed
MinRunT	Minimum Run Time	MM:SS	Demand
TimeDose	Time Dose Mode		Both

EIN-CP-REF-150
Rev 7.1 © 01/05/10

MVP-S DM CS Reference Chart

Program Code: SI115-61

Input Functions (Timed Dose):

- RO & Low Level Alarm Float
- Timer On & Off Float
- Override Timer On & Off Float
- High Level Alarm Float
- Current Sensor
- Push to Silence/Reset

Condition for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Pump is activated
- Pushbutton is pressed

Input Functions (Demand):

- RO & Low Level Alarm Float
- Off Float
- On Float
- High Level Alarm Float
- Current Sensor
- Push to Silence/Reset

Condition for activation:

- Float in up position
- Float in up position
- Float in up position
- Float in up position
- Pump is activated
- Pushbutton is pressed

Output Functions:

- Pump
- Level Light
- Pump Fail Light
- Audible Alarm

Condition for activation:

- Pump is called to run
- Alarm Light is activated
- Pump Fail Light is activated
- Audible Alarm is activated

Built In Screens:

Built in screens include: time & date, digital inputs, and digital outputs. To view these screens, press the down arrow repeatedly until a built in screen appears, then use the left and right arrow keys to change between screens.

Alarm and System Data Screens:

Alarm screens appear during alarm conditions. System data screens include float status, pump run data, and alarm activity. Screens with a "T" in the lower right contain totalized values. Screens with a "R" in the lower right contain resettable values. To change between these screens, press the up and down arrow keys.

Selecting Parameters for Viewing or Adjusting:

To begin the process to set parameters, press the down arrow repeatedly until the last screen is shown, then press 'ESC'.

Parameter Names:	Description:	Time Range:	Timed / Demand
HLA Dly	High Level Alarm Delay	MM:SS	Both
Off Time	Timer Off Time	MM:SS	Timed
On Time	Timer On Time	MM:SS	Timed
OVR Off	Override Timer Off Time	MM:SS	Timed
OVR On	Override Timer On Time	MM:SS	Timed
MinOvrTm	Minimum Override Time	MM:SS	Timed
MinRunT	Minimum Run Time	MM:SS	Demand
TimeDose	Time Dose Mode		Both

EIN-CP-REF-150
Rev 7.1 © 01/05/10